



sira

Hazardous Area Centre,
Rake Lane, Ecclestone,
Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
Fax: +44 (0) 1244 681330
Email: exhazard@sira.co.uk
Web: www.siraservices.com

TEST CERTIFICATE

ISSUED BY SIRA TEST & CERTIFICATION LIMITED

TEST FOR THE INGRESS PROTECTION OF A IRISS INFRARED WINDOW ASSEMBLY

Manufacturer: Global Maintenance Technologies Ltd
Chelford Court
Robjohns Road
Chelmsford
Essex
CM1 3AG

Model or Type Identification: IRISS Infrared Window Assembly

Standard: BS EN 60529:1992

Deviations from Standard: None

ST&C Test Procedure: LOP 220

ST&C Internal Test Report: 04/03

Sample Delivery Date: 17 June 2004

Tests Conducted Between: 17 June 2004 – 23 June 2004

This certificate refers to the performance of the test sample when tested against the agreed programme. It does not imply that any other samples or products necessarily comply with the requirements of the test programme.

Sira Test & Certification Limited being an UKAS accredited Test House in accordance with ISO/IEC 17025 certifies that the IRISS Infrared Window Assembly has been found to comply with the requirements of the Ingress Protection Code: IP 65

M Wilson
Laboratory Manager

Dated 12 July 2004

This certificate may only be reproduced in its entirety and without change

Page 1 of 1

Certificate No: Sira 51D12071A
ST&C (Chester) Form 240, Issue 5

siragroup